



Bearing of the cut platform as per table 1  
Subgrade prepared in accordance with NZS4431

600mm maximum topsoil or unsuitable material can be removed a replaced with well graded compacted hardfill. Should depths be larger than 600mm or if the hardfill can not be extended passed the bu envelope as shown, either a geotechnical engineer shall certify the platform and compacted subgrade complies with "good ground" as by this document or specific design can be completed by a struct engineer